

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0067:240

Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Siemens Building Technologies/Fire Safety Division, 8 Fernwood Rd, Florham Park NJ 07932  
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

**DESIGN:** Models U-S17-1, U-S17-1-W; U-S110-1, U-S110-1-W (20-31 VDC) non-synchronized strobe lights.

Models U-S17-1-AG, U-S17-1-AC-W; U-S110-1-AC, U-S110-1-AC-W (120 VAC) non-synchronized strobe lights.

Model U-S17S-1, U-S17S-1-W; U-S110S-1, U-S110S-1-W (20-31 VDC) synchronized strobe lights. All synchronized strobes must be used with models SCM-F, -FW or DSC, DSC-W Sync Module.

Refer to the listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction. Suitable for wall and ceiling mount.

**MARKING:** Listee's name, model number, electrical rating, and UL label

**APPROVAL:** Listed as strobe lights for use with separately listed compatible fire alarm control units. These devices are not approved for the hearing impaired applications. Models are suitable for outdoor use when used with Model FWB-1, -1W or FWB-2, -2W back box. Refer to listee's Installation Instruction Manual for details.

**XLF:** 7300-0065:161

12-17-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**DECEMBER 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager